



Purchasing Division

REQUEST FOR BID: Well Maintenance & Inspection Services Contract

ADDENDUM NO. 1

DATE: August 15, 2023

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made part of the bid document.

**EXHIBIT A
SCOPE OF WORK**

- Pull Pump & Motor
- Perform Bench Test on Motor
- Video Inspection of the Well x2 (before and after). Provide video footage to the city.
- Brush & Bail Cleaning of the Well
- Inspect Wear and Condition of the Pump
- Chlorination of Well
- Reinstall the Pump and Motor
- **Added to SOW:**
 - ***Well to be brushed for a minimum of two hours per 100 feet below the static water line.***

Well No. 6 Equipment Information Sheet

Pump Information Meter

Make Goulds

Model 14RHMC Model

Stages 2

Speed 1770 rpm

Flow 2500 gpm

Head 162 ft

Power 123 hp

Column 160' of 12"

Shaft 1.5" Diameter

Bearings 12"

Installation Date April 2011

Motor Information

Make US Motors

Model 3/60/460/WP-1

Efficiency Premium

Power 150 HP

Installation Date May 2011

Acknowledgement:

Name & Title

Firm Name

Authorized Signature & Date